

# TEST CERTIFICATE

## of the slide-blocking property in wet loaded barefoot areas of floor coverings

Tested material: **plastics**

Kind of material: shower tray - surface coated with KOLPA San anti-slip coating

Article description: shower tray with relief surface

Dimensions: according to specification: variable shape - variable length, width and depth (test specimen: 1000 x 500 x 35 [mm])

Colour description: UNI color (test specimen: WHITE)

Surface: surface coated with Kolpa anti slip coating (even, rough structured)

Surface treatment: cutted plate from shower tray

Producer/supplier: Kolpa, d.o.o. Metlika  
Rosalnice 5  
8330 Metlika  
SLOVENIJA

Client: Kolpa, d.o.o. Metlika  
Rosalnice 5  
8330 Metlika  
SLOVENIJA

Certificate No.: 94152101.001e

Test date: 03.06.2021

Sampling: Sent by the customer to the research institute

Test method: **DIN 51097**, ed. 11/92  
"Testing of floor coverings; determination of the anti-slip properties; wet-loaded barefoot areas; walking method - ramp test"  
"Requirements of the control-committee **"Slide-blocking Floorings – List NB"**"  
The delivery of the test material took place in ready-to-test surface condition.

Test result: Average inclination angle: **22°**

Assessment: **Assessment group of anti-slip property: B**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

*F. Höltkemeyer*  
Dipl.-Ing. Friedrich Höltkemeyer



Großburgwedel, 07.06.2021  
Schu/ed

This test-certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test-specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this report is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –

**SÄUREFLIESNER-VEREINIGUNG E. V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (051 39) 99 82-0 · Telefax (051 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00 aufgeführten Bereiche. Vom DIBT nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

